

# Evidence of Performance

## Single axis hinges as per EN 1935 : 2002



Test Report  
 Nr. **13-002961-PR01**  
 (PB-G02-03-en-02)

**Client** ARGENT ALU nv  
 Bankstraat 2  
 9770 Kruishoutem  
 Belgium

**Basis**  
 EN 1935 : 2002  
 Test standards:  
 EN 1935 : 2002

**Product** Single axis, two-piece blade door hinge

Corresponding national versions (e.g. DIN EN)

**Designation** Aluminium LIFT OFF HINGE 80/80

Test Report No.: 13-002961-PR01 (PB-G02-03-en-01) dated 7.1.2014

**Leistungsrelevante Produktdetails**  
 Length of hinge: 80 mm;  
 Material of hinge: Aluminium  
 Material of hinge pin: Stahl, galvanized;  
 Diameter of hinge pin: 8,0 mm;  
 Knuckle diameter: 14,0 mm,  
 Blade thickness: 3,5 mm

**Representation**

**Assembly and maintenance** According to maintenance and assembly instructions of Hardware manufacturer.

**Special features** -/-



**Instructions for use**

This test report demonstrates compliance with the requirements for hinges as per EN 1935: 2002.

**Result**

Classification as per EN 1935 : 2002

Category of use	Durability	Mass of test element	Fire resistance	Safety	Corrosion resistance	Security	Hinge grade
4	7	5	1	1	4	0	12

This test report does not replace the EC Certificate of Conformity.

Observe the provisions of EN 1935: 2002 for marking and evaluation of conformity of construction products.

**Validity**

The data and detailed results given refer solely to the tested and described test specimens. Classification remains valid as long as the product and the above basis remain unchanged. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented; in particular the effects of weathering and ageing were not taken into account.

**Notes on publication**

The ift Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies. The cover sheet can be used as abstract.

The report comprises a total of 16 page.

ift Rosenheim  
 10.01.2014

Alexander Sauer, Dipl.-Ing. (FH)  
 Operating Product Officer  
 Division Building Components

Gerd Steiner  
 Test Engineer  
 Safety Engineer